



WAREHAM WATER POLLUTION CONTROL FACILITY

6 Tony's Lane
Wareham, MA 02571
Telephone (508) 295-6144
Fax (508) 291-0155

#14-IFB-003

COATING SYSTEM FOR SECONDARY CLARIFIERS (2)

October 31, 2014

PROJECT: Coating System for Secondary Clarifiers (2)
DATE ISSUED: October 15, 2014

ADDENDUM NO. 1

The specification documents for the above-referenced project are hereby amended and/or clarified as per the particular listed below:

**Change Sauereisen Product:
Restokrete 120 to Restokrete 208 epoxy-modified resurfacer
And add Sauereisen 210X.**

Only epoxy/modified build back materials to be used.

Repair mortar and epoxy topcoat must share to same epoxy matrix to ensure a bonded weld at the molecular leveling order to prevent migration of bacteria and sewer gasses throughout the monolithic system.

BIDDER MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING BELOW AND INCLUDING THIS ADDENDUM IN THEIR BID SUBMITTAL.

Signature of Authorized Bidder

Date



WAREHAM WATER POLLUTION CONTROL FACILITY

6 Tony's Lane
Wareham, MA 02571
Telephone (508) 295-6144
Fax (508) 291-0155