



ADDENDUM NO. 2
TO CONTRACT DOCUMENTS


Project	Generator Replacement at Salt Works and Terry Lane Pump Stations	Project No.	11206153
Owner	Town of Wareham, MA	Federal Project No.	
Contract No.	2020-WW-01	Date	November 10, 2020

To All Contractors:

Contractors submitting proposals for the above-named project shall take note of the following changes, additions, deletions, clarifications, etc., in the Contract Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Contract Documents, and all such shall be taken into consideration and be included in the Contractor's bid proposal.

Please see attached pages.



 , P.E., BCEE

Marc R. Drainville, Principal



ITEM NO. 1.

Section 00050 Invitation to Bid, last paragraph

- A. **DELETE** the last paragraph in its entirety and **REPLACE** with the following:

“A mandatory Pre Bid Conference will be held at 10:00 a.m. on November 5, 2020 at the Wareham Wastewater Treatment Facility on Tony’s Lane in Wareham, MA for Electrical Sub Contractors. For General Contractors and Subcontractors for Miscellaneous Metals Sub Contractors, the Pre Bid Conference is non-mandatory. Representatives of Owner and Engineer will be present to discuss the Project. Bidders are encouraged to attend and participate in the conference.”

ITEM NO. 2.

Section 00100 Instructions to Bidders, Article 5

- A. **DELETE** “non-mandatory” from paragraph 5.01.

ITEM NO. 3.

Section 01010 Summary of Work, paragraph 1.06.C:

- A. **ADD** new paragraph following 1.06.C:
“D. All local permit fees shall be waived.”

ITEM NO. 4.

Section 01500 Temporary Facilities, paragraph 1.02.C:

- A. In paragraph 1.02.C.1 **DELETE** “Not Applicable.” and **REPLACE** with “All Pumping Station Equipment.”
- B. **INSERT** new paragraph 1.02.C.2: “It is acknowledged that each of the pumping stations will be out of power during the turnover from the existing generator to the new generator. The Owner will provide and pay for pumping of the wet well for a period of up to 48 consecutive hours for each pumping station during this power shut down. For any period of time over 48-hours, the Electrical filed subcontractor is responsible for providing backup power or pumping services.”