



**Responses to Bidder Questions  
Wareham, MA WPCF Improvements – Phase I (Contract No. 2021-WW-01)**

**May 3, 2021**

The following are questions received from contractors. This is **NOT** part of the addendum. This is for informational purposes only. Please note that some questions are paraphrased or combined. Questions that in our judgment are determined to be duplicates of questions that were already answered will not be repeated.

- 1. Does the 4' x 4' sump in Equalization Basin 5 have grating over it? If so, is the grating FRP or aluminum?**

No grating is required over the 4' x 4' sump.

- 2. No diameter is provided for the observation manholes on the 1" x 3" methanol line. They scale out to approx. 24". Can you clarify diameter. Would these structures need to be designed for H2O loading? What type of access cover are you looking for?**

See Addendum No. 4 Item No. 12.

- 3. Section 02698 Paragraph 2.02.B.15 indicates dual containment pipe shall be equipped with automatic leak detection as specified in article 2.09. There is no article 2.09 in this section. Please advise.**

No leak detection shall be required. See Addendum No. 4 Item No. 5.

- 4. Section 13133 indicates support beams shall be stainless steel or aluminum beams. Please advise if FRP beams acceptable instead.**

FRP beams are acceptable. See Addendum No. 4 Items No. 6 and 11.

- 5. Section 13133 calls for the cover to be flush with top walls. Drawing S101 shows the cover panels to be top mounted. Please advise which is intended.**

The intent is that the covers are top mounted. See Addendum No. 4 Item No. 6.

- 6. Section 13133 calls for the access hatches to be FRP, however, drawing S101 calls for the access hatches to be aluminum. Please advise which is intended.**

The hatches for Equalization Basin No. 5 shall be FRP. See Addendum No. 4 Items No. 9, 10, and 11.

- 7. Can a copy of the Pre-Bid Conference Sign-In Sheet Be provided?**

The Sign-In Sheet for the Pre-Bid Meeting from April 20, 2021 has been provided, see the next page.



SIGN IN SHEET

CONTRACT 2021-WW-01 WATER POLLUTION CONTROL FACILITY IMPROVEMENTS - PHASE 1

PREBID MEETING SIGN-IN SHEET

TUESDAY, APRIL 20, 2021, 10:00 AM

TOWN OF WAREHAM WPCF, 6 TONY'S LANE, WAREHAM

NAME	AFFILIATION	ADDRESS	PHONE	EMAIL
SCOTT Mc Cabe	Marine Division ROD	24 Great Western Rd	508-326-1170	SCOTTMcCabe707@gmail.com
Bill Dutton	WES Const.	650 Industrial Dr Haverhill	508-328-2082	BDUTTON@WESCONSTRUCTION.com
Ryan Mell	Sparks Co. Inc	15 Simmons Pk Little Compton RI 02887	401-635-2440 508-679-0518	rmell@sparkscompanyinc.com
MICHAEL BIZKO	Biszko Building	20 Development St Fall River MA 02701	508-679-0518	mike@BiszkoCorp.com
Jeff Zitzler	Waterline	07 London Ln Scabrick NH	603-474-7477	jzitzler@waterline.com
JOSH LEWIS	WINSTON BLDS	55 Hopkinton Rd Westboro MA	508-366-1707	Josh.winston@verizon.net