

Re: Comprehensive Permit 40b - Littleton Dr.

Fire Prevention <fireprevention@warehamfiredistrict.org>

Wed 12/9/2020 3:30 PM

To: Sonia Raposo <sraposo@wareham.ma.us>;

Sonia

We will be looking for a site plan including hydrant locations, emergency vehicle turning radius analysis, and Fire department emergency access. We will need this information to provide a proper review.

Respectfully,

Fire Prevention

Wareham Fire Department

Sent from my iPhone

The information contained in this communication from the sender is confidential. It is intended solely for use by the recipient and others authorized to receive it. If you are not the recipient, you are hereby notified that any disclosure, copying, distribution or taking action in relation of the contents of this information is strictly prohibited and may be unlawful.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd**, an innovator in Software as a Service (SaaS) for business. Providing a **safer** and **more useful** place for your human generated data. Specializing in; Security, archiving and compliance. To find out more [Click Here](#).