

James V. O'Brien <jvocorp@gmail.com>

## Re: Settlers Glen, Revised Plans

David Candeias <superintendent@onsetwater.com> To: Brian Grady <a href="mailto:Srian@gafenginc.com">Srian@gafenginc.com</a>, "James V. O'Brien" <a href="mailto:jvocorp@gmail.com">jvocorp@gmail.com</a> Mon, Feb 28, 2022 at 9:15 AM

Cc: sosborne@osd-ec.com

Brian,

The plans do not show a second water main connection on Cranberry Highway as requested by the Onset Water Department. The water main on Sheet 4 is capped and restrained at the back of the sidewalk on Cranberry Highway. Per Onset's general procedures and specifications, Paragraph 1.C. Review, "[a]ny required changes must be incorporated on the drawings and resubmitted."

The proponent has not made the changes required by the department. At this time, OSD, as the District's engineer, is not able to complete the evaluation of the impact of the proposed project on the existing system and to generate an ability to serve letter. After the ability to serve evaluation has been completed, OSD will draft a letter which will include an estimate of impact fees.

Thank you, David Candeias

On 02/26/2022 10:56 AM Brian Grady <a href="mailto:spirital">brian@gafenginc.com</a>> wrote:

Mr. Candeias,

Attached is a pdf of the revised plan for Settlers Glen reflecting the determination of the Wareham Zoning Board of Appeals. A full set went out in the mail to you yesterday. Please let me know if you have any questions or need additional information.

## Thanks,

# Brian R. Grady, R.S.

## G.A.F Engineering, Inc.

266 Main Street Wareham, MA 02571

Office: 508.295.6600 | Fax: 508.295.6634

E-mail: brian@gafenginc.com



#### PRIVILEGE AND CONFIDENTIALITY NOTICE

The information in this electronic mail is intended exclusively for the above-named recipient(s) only. It may contain privileged and confidential matters. If you have received this electronic mail in error or if you are not the above-named recipient, please notify the sender immediately by replying to this electronic mail or by collect calls to 508.295.6600. Do not disclose the contents to anyone.