

Fw: Revised letter

Kenneth Buckland

Wed 7/6/2022 8:53 AM


To: Sonia Raposo <sraposo@wareham.ma.us>; Monique Baldwin <MBaldwin@wareham.ma.us>;

file with Tow Road car wash

Kenneth Buckland

Director of Planning and Community Development

Town of Wareham

 [508.291.3100](tel:508.291.3100) x 6501

From: Fire Prevention <fireprevention@warehamfiredistrict.org>

Sent: Wednesday, July 6, 2022 8:32 AM

To: john@rojocarwash.com

Cc: rlperrylaw@verizon.net; Kenneth Buckland

Subject: RE: Revised letter

Good morning,

We performed a site visit to confirm hydrant location on Cranberry Hwy as the submitted plans were not clear. There is a hydrant at the entrance to the site so the additional hydrant indicated in our review letter will not be necessary. Please let us know if you have any additional questions.

Respectfully,


Christopher Smith

Captain Fire Prevention

Wareham Fire Department

273 Main Street

Wareham Ma 02571

 [508-295-2973](tel:508-295-2973)

From: Fire Prevention
Sent: Wednesday, June 22, 2022 8:04 AM
To: john@rojocarwash.com
Subject: Revised letter

Good morning John
Attached is the revised letter.

Respectfully,

Christopher Smith
Captain Fire Prevention
Wareham Fire Department
273 Main Street
Wareham Ma 02571
 [508-295-2973](tel:508-295-2973)