

Revised Fire Department Comment

Fire Prevention <fireprevention@warehamfiredistrict.org>

Wed 8/10/2022 3:49 PM

To: Kenneth Buckland <kbuckland@wareham.ma.us>;

Cc: Sonia Raposo <sraposo@wareham.ma.us>; nperkins@wingatemanagement.com <nperkins@wingatemanagement.com>; Charles Rowley <crsr63@verizon.net>; Andrew Cunningham <acunningham@warehamfiredistrict.org>;

Good afternoon,

We were provided with a preliminary plan for this project and we responded that we had no comments. The plan provided indicated that a fire hydrant symbol on the corner. The plan on the ZBA website does not indicate a hydrant. Please provide a fire hydrant on the corner of Main Street and the entrance to the development. Please coordinate with the Wareham Water District for exact location and main size.

Respectfully,

Christopher Smith
Captain Fire Prevention
Wareham Fire Department
273 Main Street
Wareham Ma 02571
508-295-2973