

Re: ZBA# 55-21 Mannix - Site Plan Review / 238 & 240 Sandwich Road**Guy Campinha**

Mon 9/20/2021 11:30 AM

To: Sonia Raposo <sraposo@wareham.ma.us>; Fire Prevention <fireprevention@warehamfiredistrict.org>; Walter Correia Jr <walter_correia@warehampolice.com>; Patrick MacDonald <pmacdonald@wareham.ma.us>; Robert Ethier <rethier@wareham.ma.us>; David Riquinha <DRiquinha@wareham.ma.us>; David Evans <devans@wareham.ma.us>; David Candeias <superintendent@onsetwater.com>; David Menard <dmenard@wareham.ma.us>; Charles Rowley <crsr63@verizon.net>; David Pichette <dpichette@wareham.ma.us>; BOS <bos@wareham.ma.us>; Kenneth Buckland <kbuckland@wareham.ma.us>; snigerr.onsetfd@gmail.com <snigerr.onsetfd@gmail.com>;

Cc: Michael A Baptiste Sr <shellyandmike@yahoo.com>; Michael King <mking1568@gmail.com>; Richard Swenson <swensr@gmail.com>; Sam Corbitt <scorbitt10@gmail.com>; Carl Schulz <carlschulz@protonmail.com>;

Good morning. Sewer commissioners have approved the sewer connection and there are conditions.
Impact study to linwood pump station.

Explore the possibility of gravity (done and pump station needed)

address nonflushables using a grinder system

have the ability of residents and business to connect to the force main

engineering updates as to project progress and changes that need to be addressed.

The pump station from property will go down route 6 to linwood avenue to the manhole and gravity to linwood pump station.

Any elevated H₂SO₄ (hydrogen sulfide) issue will need to be addressed at pump station.

Any issues that come about that has not been discussed and has an impact to sewer must be address before going on line.

Thank you

Best,

Stay safe,

Guy

Guy Campinha Sr.

Director WPCF

Wareham, Ma 02571

508-295-6144 EXT 4001

cell# 508-958-4290
