



## WAREHAM WATER POLLUTION CONTROL FACILITY

6 Tony's Lane  
Wareham, MA 02571  
Telephone (508) 295-6144  
Fax (508) 291-0155  
TTY: 1-800-439-2370

Guy Campinha, Director

**#16-IFB-003**

### **Wastewater Chemicals**

**June 2, 2016**

### **ADDENDUM NO. 1**

The Wareham wastewater treatment plant has changed coagulants. The coagulant now in use is Holland EPIC ww 525. All potential bidders will need to Pre-Qualify their product to demonstrate **equivalent or superior** performance and cost effectiveness.

Holland Epic ww 525 has the following specifications:

- a. Chloride: 10% minimum
- b. Sulfate: less than 2.5%
- c. Iron: less than 50 ppm
- d. Insolubles: less than 0.01%
- e. Appearance: clear to slight haze
- f. Freeze point: approximately 10 degrees F
- g. Specific Gravity: 1.30 - 1.35
- h. pH: 3.5 – 4.0 ( 1 in 20 soln)

Prospective bidders must offer technical service and support.

Product to be made in the U.S.A.

Must provide three (3) references from agencies that use your product within 75 miles of Wareham, MA that we may contact.

***BIDDER MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING BELOW AND INCLUDING THIS ADDENDUM IN THEIR BID SUBMITTAL.***

---

Signature of Authorized Bidder

Date