

# RE: Comprehensive Permit 40b - 4 Littleton Dr. - Comments needed

Guy Campinha

Tue 12/8/2020 2:43 PM

To: Sonia Raposo <sraposo@wareham.ma.us>; crsr63@verizon.net <crsr63@verizon.net>; David Evans <devans@wareham.ma.us>; Fire Prevention <fireprevention@warehamfiredistrict.org>; David Menard <dmenard@wareham.ma.us>; Robert Ethier <rethier@wareham.ma.us>; David Pichette <dpichette@wareham.ma.us>; John Walcek <john\_walcek@warehampolice.com>; Peter Flannery <peter\_flannery@warehampolice.com>;

My comment. For consistency and protecting the problem with non flushables grinder pumps will be required for each building.

Would need time line for anticipated completion and sewer flow from project

I believe the flow chart w would trigger a fee for I&I. Will verify when recieve actual flow with phasing if applies.

Because there is no latteral nor know betterment, will have to look at sewer developers fee or waiver.

Will bring all these items and more up and further discussion at sewer commissioners meeting the 10th

Any information provided to assist in those discussions would be appreciated.