

Fire Prevention <fireprevention@warehamfiredistrict.org>

Reply all |

Today, 8:29 AM

Sonia Raposo; Kenneth Buckland

Good Morning,

Thank you for the clarification. We have reviewed the Preliminary Subdivision for Zimmer Estate. The proposed paved roadway width of 20 feet and cul-de-sac radius of 61 feet meets code and will be suitable for Fire Department Access. We have no further comments at this time. Please feel free to contact our Fire Prevention office with any additional questions.

Best Regards,

Christopher Callinan

Captain Fire Prevention
Wareham Fire Department
[273 Main Street](#)
[Wareham, MA 02571](#)
508-295-2973