



WAREHAM WATER POLLUTION CONTROL FACILITY

6 Tony's Lane
Wareham, MA 02571
Telephone (508) 295-6144
Fax (508) 291-0155

#17-IFB-002

**Cleaning & Relining the Sewer Pipe
At Viking Drive (Wareham Middle School Area)
November 23, 2016**

PROJECT: Cleaning & Relining the Sewer Pipe at Viking Dr.

DATE ISSUED: November 8, 2016

ADDENDUM NO. 1

The specification documents for the above-referenced project are hereby amended and/or clarified as per the particular listed below:

Scope of Work Description

The work consists of cleaning and relining with cured in place pipe, approximately 310 feet, of 21 inch pipe of Reinforced Concrete (RCP) gravity sewer and incidental related work.

BIDDER MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING BELOW AND INCLUDING THIS ADDENDUM IN THEIR BID SUBMITTAL.

Signature of Authorized Bidder

Date